



ORDER #: _____ DATE: _____

PROJECT: _____

LOCATION: _____

CUSTOMER: _____

APPROVED: _____ DATE: _____

MODEL	R.O. OF CURB	QUANTITY
5555	48" X 48"	
5566	48" X 60"	
5578	48" X 72"	
5596	48" X 90"	
55102	48" X 96"	
6666	60" X 60"	
6678	60" X 72"	
6696	60" X 90"	
66102	60" X 96"	

FRAME & RETAINING ANGLE FINISH: MILL (STANDARD)
OTHER _____

CURB WALLS: WHITE INNER / MILL OUTER (STANDARD)

ACRYLIC GLAZING:	
OUTER	INNER
CLEAR	CLEAR
#2412 BRONZE	#2447 WHITE

CAUTION: WHEN INSTALLING THIS PRODUCT THE AREA BELOW THE UNIT MUST BE CLEAR OF OBSTRUCTIONS WHICH COULD IMPEDE THE RELEASE OF THE DOMES.



AUTOMATICALLY OPERATED ROOF VENT
4LM7 ROOF CLASS 90
INSTALLED ON A MINIMUM 9" HIGH CURB
UL LISTED UNITS ARE DESIGNED TO DROP
OUT IN LESS THAN 5 MINUTES AT 500°F
WHEN SUBJECTED TO THE STANDARD UL
793 FIRE EXPOSURE TEST.

Wasco Part of
VELUX Commercial

VELUX Wells
85 Spencer Dr, Unit A
Wells, ME 04090
1-800-88-VELUX
veluxusa.com



Skylights pose an inherent risk of injury or death from fall throughs, and the safety of others is of the utmost importance to VELUX. VELUX recommends that the customer, building owner or manager use additional protection with the skylight such as an exterior or interior safety cage, to enhance long-term safety. The building owner or manager is responsible for providing fall protection around the skylight in accordance with OSHA regulations. VELUX also recommends that the building owner or manager restrict roof access only to personnel who have been cautioned as to the location of the skylights, and warned not to sit, step or walk on the skylights.

DATE: 05/2019 DRAWING NO.: CSO REV 0 SHEET 1 OF 1

CSO DECK MOUNT SHRINK-OUT SMOKE VENT