



GENERAL NOTES:

- 1) LOW-PROFILE UNITS REQUIRE A MINIMUM 3:12 PITCH
- 2) STRUCTURAL SUPPORT REQUIRED UNDERNEATH PERIMETER AND ALL PURLINS AND RAFTERS
- 3) RAFTER LOCATION BASED ON WASCO'S RECOMMENDATIONS AND AAMA GLAZING GUIDELINES (BASED ON SIZE OF UNIT, TYPE OF GLAZING, CUSTOMER'S REQUEST, ETC.)